DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU No. 305/2011 Number DoP_ 21477

1. Unique Product identification code:

NB740-S-1B

- Type, batch, serial number or any other element allowing identification of the construction product as required by Article 11(4): Smoke alarm device NB740-S-1B
- 3. Intended use of uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer: Smoke detection and alarm equipment for residential applications.
- 4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5): Wizmart Technology Inc. 3F, #30, Sec 1, Chang-An East Road Taipei 104 Taiwan
- 5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2): Not applicable.
- System of systems of assessment and verification of constancy of performance of the construction product as set out in Annex V: System 1
- 7. In case of the declaration of performance concerning a construction product covered by the harmonized standard:

VdS Schadensverhütung GmbH, Notified Body no. 0786

performed type testing and initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:

0786-CPR-21477

- In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: Not applicable, see item 7.
- 9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performance for the intended use or uses indicated in 3. have been determined as described in the hEN mentioned in the following table.

wizMart

Essential characteristics	Performance	Harmonized Technical Specification EN 14604:2005/AC:2008
Nominal activation conditions/ Sensitivity, Response delay (response time) and	Pass	4.12, 4.18, 5.2, 5.3, 5.4, 5.5, 5.6, 5.15, 5.17, 5.18, 5.19, 5.20
Performance under fire condition		5.17, 5.18, 5.19, 5.20
Operational reliability	Pass	4.1, 4.2, 4.3, 4.4, 4.5, 4.6, 4.7, 4.8, 4.9, 4.10, 4.11, 4.13, 4.14, 4.15, 4.16, 4.17, 4.19, 5.11, 5.16, 5.22, 5.23, 5.24
Tolerance to supply voltage	Pass	5.21
Durability of operational reliability and response delay, temperature resistance	Pass	5.7, 5.8
Durability of operational reliability, vibration resistance	Pass	5.12, 5.13
Durability of operational reliability, humidity resistance	Pass	5.9
Durability of operational reliability, corrosion resistance	Pass	5.10
Durability of operational reliability, electrical stability	Pass	5.14

10. The performance of the product identified in 1. and 2. Is in conformity with the declared performance in 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of the manufacturer by:

Rock Yang, Approvals Manager 123 Tonghui Road, Ningbo, Zhejiang, China 315033

Signature Rock Yang

2019-03-15