

DECLARATION OF PERFORMANCE

**According to Construction Products Regulation EU No. 305/2011
Number DoP_232.1438**

1. Unique Product identification code:
NB326-SH
2. Type, batch, serial number or any other element allowing identification of the construction product as required by Article 11(4):
Conventional multi sensor detector smoke/ heat
NB326-SH-2, NB326-SH-2L, NB326-SH-4-12, NB326-SH-4-24
3. Intended use of uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:
Fire detection and fire alarm systems installed in and around buildings.
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):
Wizmart Technology Inc.
3F, #30, Sec 1, Chang-An East Road
Taipei 104
Taiwan
5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):
SNIDO, UNIPESSOAL LDA
Rua dos Aguadeiros, LT 15 porta 2, nº 23, Zona Industrial de Vilamoura,
Vilamoura, Faro, 8125-492 QUARTEIRA, PORTUGAL
Postcode: 8125 492
6. System of systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:
System 1
7. In case of the declaration of performance concerning a construction product covered by the harmonized standard:
DBI Certification A/S, Notified Body no. 2531
performed type testing and initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:
2531-CPR-232.1438
8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:
Not applicable, see item 7.
9. Declared performance:
All requirements including all Essential Characteristics and the corresponding performance for the intended use or uses indicated in 3. have been determined as described in the hEN mentioned in the following table.

Essential characteristics	Regulatory classes	Performance	Harmonized Technical Specification EN 54-5:2017/A1:2018
Operational reliability	A2	Pass	4.2.1 - 4.2.7
Nominal activation conditions/Sensitivity		Pass	4.3.1 - 4.3.6
Response delay (response time)		Pass	4.4.1, 4.4.2
Tolerance to supply voltage		Pass	4.5
Durability of nominal activation conditions/Sensitivity		Pass	4.6.1.1, 4.6.1.2, 4.6.2.1, 4.6.2.2, 4.6.3, 4.6.4.1 - 4.6.4.4, 4.6.5

Essential characteristics	Regulatory classes	Performance	Harmonized Technical Specification EN 54-7:2018
Operational reliability	None	Pass	4.2.1 - 4.2.8
Nominal activation conditions/Sensitivity	Threshold	Pass	4.3.1 - 4.3.3
Response delay (response time)		Pass	4.4.1, 4.4.2
Tolerance to supply voltage		Pass	4.5
Performance parameters under fire conditions		Pass	4.6
Durability of nominal activation conditions/Sensitivity		Pass	4.7.1.1, 4.7.1.2, 4.7.2.1, 4.7.2.2, 4.7.3, 4.7.4.1 - 4.7.4.4, 4.7.5

10. The performance of the product identified in 1. and 2. Is in conformity with the declared performance in 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of the manufacturer by:

Rock Yang, Approval Manager
123 Tonghui Road, Ningbo, Zhejiang, China 315033

Signature: *Rock Yang*

2021-10-26